


4 QTR 2012

Redacted non responsive

PWSID	PWSName	ETT Score	Sys has Tier 1 viols?	PWS Type	Pop Srvd	Contaminant	Date 1st Significant (>=11)	Repeat Violator Tool	Total RTCd Pts	On Path to Compliance?	Site Visit	Comment
-------	---------	--------------	-----------------------------	-------------	----------	-------------	-----------------------------------	----------------------------	----------------------	---------------------------	------------	---------



KS2015501	PRETTY PRAIRIE, CITY OF	184	Y	CWS	681	Nitrate	12/31/2008	194	4	Not on Path	1/25/12-Zach Phillips	City does not implement a formal customer water meter replacement program. City should consider implementing a formal meter replacement program in an effort to reduce water loss in the distribution system. KDHE defers the City's request for a meeting to EPA.
-----------	-------------------------	-----	---	-----	-----	---------	------------	-----	---	-------------	-----------------------	--

